



BENTEL[®]
SECURITY

DECLARATION of CONFORMITY

The BENTEL SECURITY S.R.L. - Via Gabbiano, 22 - 64013 CORROPOLI (TE)

The manufacturer declares that the electrical automatic control and delay device

J408-2 + J400-EXT

PFNCFBLEJ408-2
PFNCFBLEJ408-2NM
PFNCFBLIJ408-2
PFNCFBLKJ408-2

2Z.FIRE CONTROL PANEL J408-2 ENGLISH V.
2Z.FIRE C.PANEL J408-2/NM -NO LEXAN
2Z.FIRE CONTROL PANEL J408-2 ITALY VER.
2Z.FIRE CONTROL PANEL J408-2 ISRAEL V.

Environmental class A
Protection level IP30
Flooding zone 1
CO₂, inert gas, halogenate hydrocarbon

Expected Options:

- Delay of extinguishing signal
- Monitoring of status of components
- Emergency hold device
- Control of flooding time

Response delay activated condition: maximum 3 s

Response delay triggering of outputs: maximum 1 s

*meet requirement to the ESSENTIAL REQUISITES of DIRECTIVES
89/106/CEE and 93/68/CEE and thereby complies to the following at*

Extinguishment system: **EN 12094-1:2003**

Corropoli (TE), 24/01/2007

CE **1328**

Certificate: 1328-CPD-0068

**Il consigliere delegato
Raffaele Di Crosta**



BENTEL[®]
SECURITY

DECLARATION of CONFORMITY

The BENTEL SECURITY S.R.L. - Via Gabbiano, 22 - 64013 CORROPOLI (TE)

The manufacturer declares that the electrical automatic control and delay device

J408-4 + J400-EXT

PFNCFBLEJ408-4
PFNCFBLEJ408-4NM
PFNCFBLIJ408-4
PFNCFBLKJ408-4

4Z.FIRE CONTROL PANEL J408-4 ENGLISH V.
4Z.FIRE C.PANEL J408-4/NM -NO LEXAN
4Z.FIRE CONTROL PANEL J408-4 ITALY VER.
4Z.FIRE CONTROL PANEL J408-4 ISRAEL V.

Environmental class A
Protection level IP30
Flooding zone 1
CO₂, inert gas, halogenate hydrocarbon

Expected Options:

- Delay of extinguishing signal
- Monitoring of status of components
- Emergency hold device
- Control of flooding time

Response delay activated condition: maximum 3 s

Response delay triggering of outputs: maximum 1 s

*meet requirement to the ESSENTIAL REQUISITES of DIRECTIVES
89/106/CEE and 93/68/CEE and thereby complies to the following at*

Extinguishment system: **EN 12094-1:2003**

Corropoli (TE), 24/01/2007

CE **1328**

Certificate: 1328-CPD-0068

**Il consigliere delegato
Raffaele Di Crosta**



BENTEL[®]
SECURITY

DECLARATION of CONFORMITY

The BENTEL SECURITY S.R.L. - Via Gabbiano, 22 - 64013 CORROPOLI (TE)

The manufacturer declares that the electrical automatic control and delay device

J408-8 + J400-EXT

PFNCFBLEJ408-8
PFNCFBLEJ408-8NM
PFNCFBLIJ408-8
PFNCFBLKJ408-8

8Z.FIRE CONTROL PANEL J408-8 ENGLISH V.
8Z.FIRE C.PANEL J408-8/NM -NO LEXAN
8Z.FIRE CONTROL PANEL J408-8 ITALY VER.
8Z.FIRE CONTROL PANEL J408-8 ISRAEL V.

Environmental class A
Protection level IP30
Flooding zone 1
CO₂, inert gas, halogenate hydrocarbon

Expected Options:

- Delay of extinguishing signal
- Monitoring of status of components
- Emergency hold device
- Control of flooding time

Response delay activated condition: maximum 3 s

Response delay triggering of outputs: maximum 1 s

*meet requirement to the ESSENTIAL REQUISITES of DIRECTIVES
89/106/CEE and 93/68/CEE and thereby complies to the following at*

Extinguishment system: **EN 12094-1:2003**

Corropoli (TE), 24/01/2007

CE **1328**

Certificate: 1328-CPD-0068

**Il consigliere delegato
Raffaele Di Crosta**