



BENTEL[®]
SECURITY

DECLARATION of CONFORMITY

The BENTEL SECURITY S.R.L. - Via Gabbiano, 22 - 64013 CORROPOLI (TE)

The manufacturer declares that the electrical automatic control and delay device

J424-8 + J400-EXT

PFNCFBLEJ424-8
PFNCFBLEJ424-8NM
PFNCFBLIJ424-8

EXPANDABLE FIRE C.PANEL J424-8 -ENGLISH
EXPANDAB.FIRE C.PANEL J424-8/NM NO LEXAN
EXPANDABLE FIRE CONT.PANEL J424-8

Environmental class A
Protection level IP30
Flooding zones 1 to 2
CO₂, inert gas, halogenate hydrocarbon

Expected Options:

- Delay of extinguishing signal
- Monitoring of status of components
- Emergency hold device
- Control of flooding time

Response delay activated condition: maximum 3 s

Response delay triggering of outputs: maximum 1 s

*meet requirement to the ESSENTIAL REQUISITES of DIRECTIVES
89/106/CEE and 93/68/CEE and thereby complies to the following at*

Extinguishment system: **EN 12094-1:2003**

Corropoli (TE), 24/01/2007

CE **1328**

Certificate: 1328-CPD-0068

**Il consigliere delegato
Raffaele Di Crosta**